

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 19

Dated : 02/4/26

It is certified that an inspection team headed by Dr. C. S. Tolia (Name of Officer with Designation) From Nagar Nigam Haldwani-Kathgodam (Name of Department/ Office) inspected the KIDE Convent International School (Name & Address of the School) on 02/04/2026 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No. SDLW&TML/UTSI dated 02/04/2026 of 01/04/2027 (PHED Lab) certified that the KIDE Convent International School (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt. KCS-46

The above valid for a period of 1 Year.

Signature with Seal :

Name :

Designation :

Name & Address of the office / Department:

2/04/26
वरिष्ठ नगर स्वास्थ्य अधिकारी
नगर निगम हल्द्वानी-काठगोदाम

To,

KIDE CONVENT INTERNATIONAL SCHOOLHALDWANINAINITAL

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Sub Divisional Level Water Quality Testing Laboratory

UTTARAKHAND JAL SANSTHAN HALDWANI, NAINITAL

Name of the Customer/ Organization:	Kide Convent International School Ranibagh Distt:- Nainital	Sample Description	Kide Convent International School Ranibagh Distt:- Nainital
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis End of analysis	24-03-2026 25-03-2026
Sample Code:	SDLWQTML/UJS/KCS-46	Sample collected By	Customer
Sample Receiving Date and Time:	24.03.2026 2.30 PM	Date of Issue Report	25-03-2026

Water Quality Test Report Testing Details

S.N.	Parameters	Acceptable Limit (As per BIS 10500-2012)	Permissible Limit (in the Absence of alternative source) (As per BIS 10500- 2012)	Results
1	Colour (Hazen units)	5	15	1
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.81
4	Alkalinity as CaCO ₃ (mg/l)	200	600	166
5	Turbidity (NTU)	1	5	0.61
6	Total dissolved solid (mg/l)	500	2000	270
7	Chloride (mg/l)	250	1000	5.4
8	Total hardness (mg/l)	200	600	195
9	Calcium(as ca) (mg/l)	75	200	47.8
10	Magnesium (mg/l)	30	100	18.34
11	Total coliform (MPN/100ML)	ABSENT	ABSENT	ABSENT
12	E.Coli (MPN/100 ML)	ABSENT	ABSENT	ABSENT

CHEMIST,
(Surendra Singh)
SDLWQTML
UJS Haldwani (Nainital)

Water Quality Testing & Monitoring Laboratory
UJS- Haldwani (Nainital)

Technical Manager
(Er, Ravindra Kumar)
In-Charge of Laboratory
UJS Haldwani (Nainital)

TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)